



SAND SIEVE TEST RESULTS

CLIENT:	HUGH KING & CO LTD	RESULTS TO:	MAB
		SAMPLE NO:	A9868/1
DESCRIPTION:	WASHED DUNE SAND	DATE:	07/09/2011

Category	Diameter mm	%	Diameter mm	% Passing
Stones	>8.0	0	8.0	100
Coarse gravel	8.0-4.0	0	4.0	100
Fine gravel	4.0-2.0	0	2.0	100
Very coarse sand	2.0-1.0	T	1.0	100
Coarse sand	1.0-0.5	2	0.5	98
Medium sand	0.5-0.25	55	0.25	43
Fine sand	0.25-0.125	42	0.125	1
Very fine sand	0.125-0.063	T	0.063	1
Silt + clay	<0.063	1		
Lime content (as CaCO ₃)	%	NIL		

T = TRACE



THESE RESULTS PERTAIN ONLY TO THE SAMPLE(S) SUBMITTED AND TESTED